

# Confirmation sheet

Fire classification and calorific value of  
**PA 66 GF25, dry impact resistant**

# Confirmation sheet

## Fire classification and calorific value of PA 66 GF25, dry impact resistant

### Reaction to fire classification

according to EN 13501-1

We confirm that, unmanufactured material used by Technoform Bautech to produce insulating strips PA 66 GF25, dry impact resistant conforms to the requirements of "reaction to fire class E" according to EN 13501-1.

The test has been carried out with insulating strips with a wall-thickness of 2,1 mm and 1,6 mm in accordance to EN ISO 11925-2.

### Confirmation of calorific value

We hereby confirm the calorific value of the raw material PA 66 GF25, dry impact resistant processed by Technoform Bautech:

**Hi = 23 MJ/kg**

Reference standard DIN 51900